

Newmark/Muscoy Team Conference Call Notes

11 March 2005 (2:00 P.M.)

Conference Call Members Present for Call:	
Dwayne Deutscher/URS □ Dennis Bane/URS □ Matt Dwyer/URS □ Adam Harvey/URS □ Connie Biedel/URS □ Kit Veldman/URS □ Tim Gere/URS □ Tom Perina/CH2M Hill □ Bob Kemmerle/E2	 ☐ Kim Hoang/EPA ☐ Jackie Lane/EPA ☐ Francisco Arcaute/EPA ☐ Sunny Nelson / EPA ☐ Stacey Aldstadt/SBMWD ☐ Bill Bryden/SBMWD ☐ Russell Smith/SBMWD ☐ Mark Eisen/SBMWD ☐ Terry Tonn/SBMWD ☐ Mike Lowe/SBMWD ☐ Lana Kennerly/SBMWD

| Construction [Matt Dwyer]

- The chlorine system is now operational.
- The SCADA control still has to be completed.
- Continuing with the electrical modifications.
- Davis is finishing up with the electrical mods today.
- Nick is working with Mike Worthington to write specific scope of work for ATSI for the changes to the chlorine system.
- EL-Co began installation of the differential transmitters last week and will continue this week.
- The equipment from MUNI for the SCADA system has been installed by Davis.
- When Matt receives letter approving the probe for the vault, he will get working on it (Lana mailed hard copy last week).

EW-112 and GAC Vessel

- Matt will call Nick to investigate the leaking that Bill observed on the 1-1/2 or 2" stainless steel pipe on Vessel 9A.
- EW-112 has been clean now for 2-3 weeks.
- Mike Lowe will be signing off on the shake-down and punch-list after getting carbon vessels cleaned up.
- Matt will check with Adam on the schedule timeline and advise Kim.

General

Bill said he got the tile for the façade house on Garner.

Community

None

Next Conference Call

Monday, 18 April 2005; Call in #: 202-275-0170; Participant Code: 7860 (#).

The minutes of this meeting represent the writer's understanding of the events as discussed. Should an attendee's understanding differ, please contact Dwayne Deutscher at 916-679-2051, or dwayne_deutscher@urscorp.com. The minutes contained herein will stand if not corrected within ten (10) days of this writing.